

NO-NC/PMC/YD/2019-20/W3-4V

Date: 29-01-2020

To,
The Executive Engineer,
Yelahanka Division,
Bangalore.

"PMC CERTIFICATE AND INSPECTION REPORT"

Dear Sir

Subject: Regarding Inspection Report for the below mentioned work.

Name of Work: Improvements to roads and construction of RCC drains at Attur Village and surrounding areas in Ward No. 03

Item No	Description of work	Unit	Qty
1	KSRRB 300 - Excavation for road, drains and similar works KSRRB 300-1. Earthwork excavation by manual means in ordinary soil involving an average	Cum	1192.07
2	KSRRB M2100-10. Providing and laying Plain cement concrete of mix 1:3:6 with OPC @ 220kgs, with crushed 40mm and down size graded granite	Cum	198.85
3	Providing and laying plain/reinforced cement concrete for side drains using M20 nominal mix concrete with OPC at 300 kgs. With 20mm and down size	Cum	383.57
4	KSRRB - M2300-14: Providing TMT steel reinforcement for R.C.C work including straightening, cutting, bending, hooking, placing in position,	Ton	27.12
5	Providing and fixing RCC precast cover slab of 100mm thick for drain in cement concrete 1:1.5:3 using graded granite jelly 20mm and down size	Sqm	974.93
6	Providing and fixing RCC precast cover slab of 250mm thick made out of CC 1:2:4 and jelly 20mm and down size with steel reinforcement, including	Nos	21.45

With respect to the above subject & name of the work, we have inspected the work and the Quantity and Quality of above mentioned items of the work was found to be completed satisfactorily for the 1st and Final bill.

Thanking you,

With Regards

For Newzen Consultants Bangalore

